

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 125/D/ SWA/NSA

Dated: 11/6/2026

It is certified that an inspection team headed by ALKA SINGH - CHEMIST..... (Name of Officers with designation) from KANPUR NAGAR NIGAM..... PHED inspected the GULMOHAR, 651 - W. Block, Keshav Nagar, Kanpur..... (Name & Address of the school) on 08/6/2026..... (date of inspection) and on the basis of Water Test Report (Attached) bearing no. 429/ SWA/ CHEM.... dated 11/06/2026 of Public Health Laboratory, Kanpur Nagar Nigam (PHED Lab) certified that the GULMOHAR..... (Name of school) has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till ONE YEAR.....

Signature with Seal:

Name

Designation

Name & Address of the Officer/ Department

Alka Singh
Dr. Alka K. Shukla
नगर स्वास्थ्य अधिकारी
नगर निगम कांपुर

To

GULMOHAR.....
651 - W. Block, Keshav Nagar Kanpur.
 (Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

64 | Page

GULMOHAR
Rohit Jaiswal
 MANAGER

Principal
GULMOHAR
651, W-Block, Keshav Nagar,
KANPUR



KANPUR NAGAR NIGAM

PUBLIC HEALTH LABORATORY NAGAR NIGAM KANPUR

Result of Bacteriological Examination of Water Sample taken from GULMOHAR, 651- W Block Keshav Nagar, Kanpur

Name & designation of the person collecting samples: ALKA SINGH - Chemist

Date & time of collection	Source of sample	Colony count on Agar Agar per M.L. of water		Presumptive Coliform count			Probable on of coliform organism in 100 CC of original water	Free Residual Chlorine part per Million	REMARKS
		at 37°C in 48 hours	at room temp- return in 72 hours	50ML 1	10 ML 5	1 ML 5			

08/6/2026 GULMOHAR, 651- W Block Keshav Nagar, Kanpur Nil Nil Nil Zero Nil Good
(R.O. Water)

Copy for Information Forwarded to (1)

GULMOHAR, 651- W Block Keshav Nagar, Kanpur
GULMOHAR

(2) M.S.A. Kaulur Nagar Nigam

GULMOHAR

Kavita
MANAGER

651, W-Block, Keshav Nagar,
KANPUR

Principal
GULMOHAR

ALKA SINGH
(Chemist)
Nagar Nigam Kanpur





KANPUR NAGAR NIGAM

PUBLIC HEALTH LABORATORY KANPUR NAGAR NIGAM

Chemical water analysis report for the ^{NIS} GULMOHAR, 651-W Block Keshav Nagar
Kanpur

Sample taken from — — — SUBMERGIBLE — — —

Date of sample Drwn — — — 09/6/2026 — — —

Date of analysis — — — 20/6/2026 — — —

Physical Character — — — TRANSPARENT / ODOURLESS — — —

P. H. Value — — — 6.54 — — —

Free Ammonia Parts per 1000000 — — — N/A — — —

Alouninoid Ammonia Part per 1000000 — — — N/A — — —

Oxygen absorbed from pot. Permagnate
in three hours at 37° C — — — 0.00 — — —

Chloride Part per 1000000 — — — 24.00 — — —

Nitrates Parts per 1000000 — — — NIL — — —

Nitrates Parts per 1000000 — — — NIL — — —

Total solid part per 100000 — — — 210.00 — — —

Fixed solid Parts per 1000000 — — — 106.00 — — —

Volatils solid Parts per 100000 — — — 24.00 — — —

Appearance on ignition — — — No Charring — — —

Total hardness Parts per 1000000 — — — 112.00 — — —

Permanent hardness Parts per 1000000 — — — 90.00 — — —

Temporary hardness Parts per 1000000 — — — 22.00 — — —

Remarks :

POTABLE¹

No. 429/kanpur dated 11/06/2028

Copy forwarded for favour or information to

1) GULMOHAR, 651-W Block
Keshav Nagar, Kanpur.

2) N.S.A Kanpur Nagar Nigam

GULMOHAR

Xabrit Jaiswal
MANAGER

Nagar Sanstha Adhikari
Nagar Nigam Kanpur
ALKA SINGH नगर निगम कानपुर
(Chomisi)
Nagar Nigam Kanpur

Principal
GULMOHAR
651, W-Block, Keshav Nagar,
KANPUR



Scanned with OKEN Scanner



Scanned with OKEN Scanner